



# Compliance Statement

## Unscreened Category 5<sup>+</sup> (Cat. 5e) EN & ISO/IEC Communication Patch Cable

### Copartner Identification CM

Category 5<sup>+</sup>, Patch, Unscreened  
100 W, 4 Twisted Pairs, 24 AWG, Flame Retardant, Copper Cable

**Copartner Wire & Cable Mfg. Co., Ltd.**  
**FL4, No. 16, Chien Pa Road, Chung Ho City**  
**Taipei Hsien, Taiwan**

*Compliance Statement No. 101171*

*This Unscreened ISO/IEC, EN & TIA/EIA Communication Patch Cable has been tested by 3P Third Party Testing and complies with the Category 5 performance requirements of the ISO/IEC Generic Cabling Standard 11801 and CENELEC Generic Cabling Standard EN 50173, including the draft 2nd edition Category 5:2000+ specifications, the Category 5e requirements of IEC draft Cable Standard 61156-6 and ANSI/TIA/EIA Generic Cabling Standard 568-B.2, and the CENELEC Screened Cable Standard EN 50288-3-2, including the 2nd edition draft. Flame retardancy is verified according to IEC 60332-1. The cable has EMC Performance Rating 5. The Compliance Statement may be suspended or withdrawn if cable fails to pass a Maintenance Testing performed at 6 or 12 months intervals.*

Hoersholm, 2 November 2001

A handwritten signature in blue ink, appearing to read "Ole Lambertsen".

Ole Lambertsen  
Test Responsible

Hoersholm, 2 November 2001

A handwritten signature in blue ink, appearing to read "Poul Villien".

Poul Villien  
Coordinating Manager